



**Member Generator System
Interconnected Renewable Generation
Annual Test**

Date of Inspection: _____ Time: _____

Inspected by: _____

Member Name: _____

Address: _____

City, State, Zip: _____

Type & Size of System: _____

Annual Test to Be Completed By Member

Take voltage measurement at disconnect with generation on. _____ V

With voltmeter on generator side of disconnect, open the disconnect.

Did the voltage go to zero withing 2 second? YES (PASS) ____ NO (FAIL) ____